

Utah Department of Environmental Quality

Division of Drinking Water

Public Water System Inventory Report

Run Date:
08/04/2011 12:00 pm

PWS ID: UTAH10013 **Name:** DEAD HORSE POINT
Legal Contact: UTAH STATE PARKS SOUTHEAST REGI
TIM SMITH
Address: 1165 S HWY 191 SUITE 7
MOAB, UT 84532-3062
Phone Number: 435-259-3750
City Served (Area):
County: GRAND COUNTY
System Type: Non-community
Activity Status Cd: Active
Population: 25
Rating: Approved
Rating Date: 02/03/2010
Activity Status: Active
Last Inv Update: 08/01/2010
Last Snty Srv Dt: 04/30/2008
Surveyor: MICHAEL S MOSS
Oper Period: 1/1 to 12/31

Gal/Day **Gal/Min**

Avg Daily Prod:

Total Dsgn Cap:

Total Emerg Cap:

Contacts

Contact Type	Name	Title	Office	Phone Numbers	Emergency	Email Address
AC	SMITH, TIM	SE REGION MA	435-259-3750			TIMSMITH@UTAH.GOV

Service Connections

Connection Type	Meter Type Code	Meter Size	Number Connections
Combined	Unmetered	0	9
			9 Total Svc Connections

Storage

Total Storage: 30,000 GAL **Number of Units:** 10 **Adequate Capacity:** NO

No.	Name	Type	Effective Volume	Constr Matrl	Overflow Elev	Activity Status	Press'd
ST009	VISITOR CENTER TANK 1	Underground	10,000 GAL	Fiberglass		P	
ST010	VISITOR CENTER TANK 2	Underground	10,000 GAL	Fiberglass		P	
ST007	ENTRANCE FEE STATION	Ground	2,000 GAL			A	NO
ST004	VISITOR CENTER HYDROPNEUMAT	Hydropneuma		Steel		A	YES
ST005	POINT HYDROPNEUMATIC	Hydropneuma		Steel		A	YES
ST006	GROUP SITE HYDROPNEUMATIC	Hydropneuma		Steel		A	YES
ST001	VISITOR CENTER TANK	Ground	20,000 GAL	Steel		A	NO
ST002	POINT TANK	Ground	6,000 GAL	Steel		A	NO
ST003	GROUP SITE TANK	Ground	2,000 GAL	Steel		A	NO
ST008	ENTRANCE FEE STATION HYDROPI	Hydropneuma				A	YES

Distribution System

Pump Type	Total Dyn Head ft H2O P.S.I.	Pressure Adequate	Cross Connection	Auhority Statement
No				

Sources

No.	Source Name	Activity Status	Source Type	Well Dia.	Safe Yield *	Pump Capacity	Location Data On File	Water Type	Availability	Period of Operation	Grnd Wtr Indicator
WS001	UTAH10003 MOAB CITY (HA	Active	CC				No	GW	Permanent	1/1 to 12/31	

*Reports measured flow for wells, approved design capacity for all other sources.